

Concrete Engineering Incorporated

#57 Coarse Aggregate Sieve Analysis Report

Date: 4/10/08

Source: Woodbridge Crushed #57

% Passing Specifications

Sieve Size	Weight	Cumulative	% Retained	% Passing	VDOT	ASTM	MDSHA
1 1/2"	0.00	0.00	0.0	100.0	100	100	100
1.0"	0.00	0.00	0.0	100.0	90-100	95-100	95-100
3/4"	305.00	305.00	10.7	89.3	N/T	N/T	N/T
1/2"	1454.00	1759.00	61.9	38.1	26-60	25-60	25-60
3/8"	650.00	2409.00	84.8	15.2	N/T	N/T	N/T
#4	339.00	2748.00	96.8	3.2	0-7	0-10	0-10
#8	11.00	2759.00	97.1	2.9	0-3	0-5	0-5
Pan	81.00	2840.00	100.0	0.0			
Original Wt.	2840.00						
% Difference	0.00%						